

# Blake Fire & Security Systems

Fire & Intruder Alarms, CCTV & Access Control Specialist  
Emergency Lighting, Fire Extinguishers, PAT Testing  
Part of Blake Contractors Ltd

403 Sutton Road, Southend-on-Sea, Essex SS2 5PQ  
Tel: (01702) 613641  
E-mail: info@blakefire-security.co.uk

BS5839 Part 1:2017

## Fire Detection & Alarm System Maintenance Certificate

The Entire **Fire Alarm System** at:

**H W Wilson Ltd**

North Road 14, South Ockendon, RM15 6QL

has been tested and maintained in accordance with:  
**BS5839 Part 1:2017**

by **Blake Fire & Security** for the contracted period up to:

**01/01/20**

The system is working "as designed" and any remedial works recommended are detailed on our call docket:

(58458).

Relevant works and defects have been recorded in the System Log Book.

During the past 12 months, 0 false alarms have occurred (documented in Log Book) equating to 0 false alarms per 100 automatic fire detectors per annum.

**Engineer Name:**

Mick Squires

**Engineer Signature:**



**Date of Annual Maintenance:**

20/03/19